

Mr. Guy Rainwater
Kimball Office Furniture - Salem
200 Kimball Boulevard
Salem, Indiana 47167

Re: Minor Source Modification No:
175-11390-00007

Dear Mr. Rainwater:

Kimball Office Furniture - Salem applied for a Part 70 operating permit on June 4, 1996 for a wood furniture manufacturing facility. An application to modify the source was received on September 29, 1999. Pursuant to 326 IAC 2-7-10.5 the following emission units are approved for construction at the source:

One (1) touch up/repair/special project spray booth, identified as SB21, equipped with dry filters and exhausting to two stacks, SB21A and SB21B.

The proposed Minor Source Modification approval will be incorporated into the pending Part 70 permit application pursuant to 326 IAC 2-7-10.5(l)(3). The source may begin operation upon issuance of the source modification approval.

This decision is subject to the Indiana Administrative Orders and Procedures Act - IC 4-21.5-3-5. If you have any questions on this matter call (800) 451-6027, press 0 and ask for Kimberly Titzer or extension (3-8396), or dial (317) 233-8396.

Sincerely,

Paul Dubenetzky, Chief
Permits Branch
Office of Air Management

Attachments

kt

cc: File - Washington County
U.S. EPA, Region V
Washington County Health Department
Air Compliance Section Inspector - Ray Schick
Compliance Data Section - Karen Nowak
Administrative and Development - Janet Mobley
Technical Support and Modeling - Michele Boner

PART 70 MINOR SOURCE MODIFICATION OFFICE OF AIR MANAGEMENT

**Kimball Office Casegoods Manufacturing - Salem
200 Kimball Boulevard
Salem, Indiana 47167**

(herein known as the Permittee) is hereby authorized to construct and operate subject to the conditions contained herein, the emission units described in Section A (Source Summary) of this approval.

This approval is issued in accordance with 326 IAC 2 and 40 CFR Part 70 Appendix A and contains the conditions and provisions specified in 326 IAC 2-7 as required by 42 U.S.C. 7401, et. seq. (Clean Air Act as amended by the 1990 Clean Air Act Amendments), 40 CFR Part 70.6, IC 13-15 and IC 13-17.

Source Modification No.: 175-11390-00007	
Issued by: Paul Dubenetzky, Branch Chief Office of Air Management	Issuance Date:

TABLE OF CONTENTS

A SOURCE SUMMARY

- A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]
- A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)]
- A.3 Part 70 Permit Applicability [326 IAC 2-7-2]

B GENERAL CONSTRUCTION CONDITIONS

- B.1 Permit No Defense [IC 13]
- B.2 Definitions [326 IAC 2-7-1]
- B.3 Effective Date of the Permit [IC13-15-5-3]
- B.4 Revocation of Permits [326 IAC 2-1.1-9(5)][326 IAC 2-7-10.5(i)]

C GENERAL OPERATION CONDITIONS

- C.1 Certification [326 IAC 2-7-4(f)] [326 IAC 2-7-6(1)][326 IAC 2-7-5(3)(C)]
- C.2 Preventive Maintenance Plan [326 IAC 2-7-5(1),(3) and (13)] [326 IAC 2-7-6(1) and (6)]
- C.3 Permit Amendment or Modification [326 IAC 2-7-11] [326 IAC 2-7-12]
- C.4 Opacity [326 IAC 5-1]
- C.5 Operation of Equipment [326 IAC 2-7-6(6)]
- C.6 Performance Testing [326 IAC 3-6][326 IAC 2-1.1-11]
- C.7 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]
- C.8 Compliance Monitoring Plan - Failure to Take Response Steps
- C.9 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5]
- C.10 Monitoring Data Availability [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)]
- C.11 General Record Keeping Requirements [326 IAC 2-7-5(3)]
- C.12 General Reporting Requirements [326 IAC 2-7-5(3)(C)]

D.1 FACILITY OPERATION CONDITIONS - Spray Booth (SB21)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

- D.1.1 Volatile Organic Compounds [326 IAC 8-2-12]
- D.1.2 PSD Minor Limit [326 IAC 2-2][40 CFR 52.21]
- D.1.3 Particulate Matter Emissions Limitations [326 IAC 6-3-2(c)]
- D.1.4 Preventative Maintenance Plan [326 IAC 2-7-5(13)]

Compliance Determination Requirements

- D.1.5 Testing Requirements [326 IAC 2-7-6(1),(6)][326 IAC 2-1.1-11]

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

- D.1.6 Particulate Matter (PM)
- D.1.7 Monitoring

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

- D.1.8 Record Keeping Requirements

Certification

SECTION A

SOURCE SUMMARY

This approval is based on information requested by the Indiana Department of Environmental Management (IDEM), Office of Air Management (OAM). The information describing the emission units contained in conditions A.1 through A.2 is descriptive information and does not constitute enforceable conditions. However, the Permittee should be aware that a physical change or a change in the method of operation that may render this descriptive information obsolete or inaccurate may trigger requirements for the Permittee to obtain additional permits or seek modification of this approval pursuant to 326 IAC 2, or change other applicable requirements presented in the permit application.

A.1 General Information [326 IAC 2-7-4(c)] [326 IAC 2-7-5(15)]

The Permittee owns and operates a stationary wood furniture manufacturing facility.

Responsible Official: Mr. Keith Beatty
Source Address: Hwy. 56 East, Salem, Indiana 47617
Mailing Address: 200 Kimball Boulevard, Salem, Indiana 47167
SIC Code: 2521
County Location: Washington
County Status: Attainment for all criteria pollutants
Source Status: Part 70 Permit Program
Major Source, under PSD;
Major Source, Section 112 of the Clean Air Act

A.2 Emission Units and Pollution Control Equipment Summary [326 IAC 2-7-4(c)(3)] [326 IAC 2-7-5(15)]

This stationary source is approved to construct and operate the following emission units and pollution control devices:

- (a) One (1) touch up/repair/special project spray booth, identified as SB21, equipped with dry filters and exhausting to two stacks, SB21A and SB21B.

A.3 Part 70 Permit Applicability [326 IAC 2-7-2]

This stationary source is required to have a Part 70 permit by 326 IAC 2-7-2 (Applicability) because:

- (a) It is a major source, as defined in 326 IAC 2-7-1(22);
- (b) It is a source in a source category designated by the United States Environmental Protection Agency (U.S. EPA) under 40 CFR 70.3 (Part 70 - Applicability).

SECTION B GENERAL CONSTRUCTION CONDITIONS

B.1 Permit No Defense [IC 13]

This approval to construct does not relieve the Permittee of the responsibility to comply with the provisions of the Indiana Environmental Management Law (IC 13-11 through 13-20; 13-22 through 13-25; and 13-30), the Air Pollution Control Law (IC 13-17) and the rules promulgated thereunder, as well as other applicable local, state, and federal requirements.

B.2 Definitions [326 IAC 2-7-1]

Terms in this approval shall have the definition assigned to such terms in the referenced regulation. In the absence of definitions in the referenced regulation, any applicable definitions found in IC 13-11, 326 IAC 1-2 and 326 IAC 2-7 shall prevail.

B.3 Effective Date of the Permit [IC13-15-5-3]

Pursuant to IC 13-15-5-3, this approval becomes effective upon its issuance.

B.4 Revocation of Permits [326 IAC 2-1.1-9(5)][326 IAC 2-7-10.5(i)]

Pursuant to 326 IAC 2-1.1-9(5)(Revocation of Permits), the Commissioner may revoke this approval if construction is not commenced within eighteen (18) months after receipt of this approval or if construction is suspended for a continuous period of one (1) year or more.

SECTION C GENERAL OPERATION CONDITIONS

C.1 Certification ~~[326 IAC 2-7-4(f)]~~~~[326 IAC 2-7-6(1)]~~~~[326 IAC 2-7-5(3)(C)]~~

- (a) Where specifically designated by this approval or required by an applicable requirement, any application form, report, or compliance certification submitted under this approval shall contain certification by a responsible official of truth, accuracy, and completeness. This certification, shall state that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.
- (b) One (1) certification shall be included, on the attached Certification Form, with each submittal.
- (c) A responsible official is defined at 326 IAC 2-7-1(34).

C.2 Preventive Maintenance Plan ~~[326 IAC 2-7-5(1),(3) and (13)]~~ ~~[326 IAC 2-7-6(1) and (6)]~~ ~~[326 IAC 1-6-3]~~

- (a) If required by specific condition(s) in Section D of this approval, the Permittee shall prepare and maintain Preventive Maintenance Plans (PMP) within ninety (90) days after issuance of this approval, including the following information on each facility:
 - (1) Identification of the individual(s) responsible for inspecting, maintaining, and repairing emission control devices;
 - (2) A description of the items or conditions that will be inspected and the inspection schedule for said items or conditions;
 - (3) Identification and quantification of the replacement parts that will be maintained in inventory for quick replacement.

If due to circumstances beyond its control, the PMP cannot be prepared and maintained within the above time frame, the Permittee may extend the date an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Management
100 North Senate Avenue, P. O. Box 6015
Indianapolis, Indiana 46206-6015

- (b) The Permittee shall implement the Preventive Maintenance Plans as necessary to ensure that failure to implement the Preventive Maintenance Plan does not cause or contribute to a violation of any limitation on emissions or potential to emit.
- (c) PMP's shall be submitted to IDEM, OAM, upon request and shall be subject to review and approval by IDEM, OAM. IDEM, OAM, may require the Permittee to revise its Preventive Maintenance Plan whenever lack of proper maintenance causes or contributes to any violation.

C.3 Permit Amendment or Modification ~~[326 IAC 2-7-11]~~ ~~[326 IAC 2-7-12]~~

- (a) The Permittee must comply with the requirements of 326 IAC 2-7-11 or 326 IAC 2-7-12 whenever the Permittee seeks to amend or modify this approval.
- (b) Any application requesting an amendment or modification of this approval shall be submitted to:

Indiana Department of Environmental Management
Permits Branch, Office of Air Management

100 North Senate Avenue, P.O. Box 6015
Indianapolis, Indiana 46206-6015

Any such application should be certified by the "responsible official" as defined by 326 IAC 2-7-1(34) only if a certification is required by the terms of the applicable rule

- (c) The Permittee may implement administrative amendment changes addressed in the request for an administrative amendment immediately upon submittal of the request. [326 IAC 2-7-11(c)(3)]

C.4 Opacity [326 IAC 5-1]

Pursuant to 326 IAC 5-1-2 (Opacity Limitations), except as provided in 326 IAC 5-1-3 (Temporary Alternate Opacity Limitations), opacity shall meet the following, unless otherwise stated in this approval:

- (a) Opacity shall not exceed an average of forty percent (40%) in any one (1) six (6) minute averaging period as determined in 326 IAC 5-1-4.
- (b) Opacity shall not exceed sixty percent (60%) for more than a cumulative total of fifteen (15) minutes (sixty (60) readings as measured according to 40 CFR 60, Appendix A, Method 9 or fifteen (15) one (1) minute nonoverlapping integrated averages for a continuous opacity monitor) in a six (6) hour period.

C.5 Operation of Equipment [326 IAC 2-7-6(6)]

Except as otherwise provided in this approval, all air pollution control equipment listed in this approval and used to comply with an applicable requirement shall be operated at all times that the emission unit vented to the control equipment is in operation.

Testing Requirements [326 IAC 2-7-6(1)]

C.6 Performance Testing [326 IAC 3-6][326 IAC 2-1.1-11]

- (a) Compliance testing on new emission units shall be conducted within 60 days after achieving maximum production rate, but no later than 180 days after initial start-up, if specified in Section D of this approval. All testing shall be performed according to the provisions of 326 IAC 3-6 (Source Sampling Procedures), except as provided elsewhere in this approval, utilizing any applicable procedures and analysis methods specified in 40 CFR 51, 40 CFR 60, 40 CFR 61, 40 CFR 63, 40 CFR 75, or other procedures approved by IDEM, OAM.

A test protocol, except as provided elsewhere in this approval, shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Management
100 North Senate Avenue, P. O. Box 6015
Indianapolis, Indiana 46206-6015

no later than thirty-five (35) days prior to the intended test date. The Permittee shall submit a notice of the actual test date to the above address so that it is received at least two weeks prior to the test date.

- (b) All test reports must be received by IDEM, OAM within forty-five (45) days after the completion of the testing. An extension may be granted by the IDEM, OAM, if the

source submits to IDEM, OAM, a reasonable written explanation within five (5) days prior to the end of the initial forty-five (45) day period.

The documentation submitted by the Permittee does not require certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Compliance Monitoring Requirements [326 IAC 2-7-5(1)] [326 IAC 2-7-6(1)]

C.7 Compliance Monitoring [326 IAC 2-7-5(3)] [326 IAC 2-7-6(1)]

Compliance with applicable requirements shall be documented as required by this approval. All monitoring and record keeping requirements not already legally required shall be implemented within ninety (90) days of approval issuance. The Permittee shall be responsible for installing any necessary equipment and initiating any required monitoring related to that equipment. If due to circumstances beyond its control, that equipment cannot be installed and operated within ninety (90) days, the Permittee may extend the compliance schedule related to the equipment for an additional ninety (90) days provided the Permittee notifies:

Indiana Department of Environmental Management
Compliance Branch, Office of Air Management
100 North Senate Avenue, P. O. Box 6015
Indianapolis, Indiana 46206-6015

in writing, prior to the end of the initial ninety (90) day compliance schedule, with full justification of the reasons for the inability to meet this date.

The notification which shall be submitted by the Permittee does require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Corrective Actions and Response Steps [326 IAC 2-7-5] [326 IAC 2-7-6]

C.8 Compliance Monitoring Plan - Failure to Take Response Steps [326 IAC 2-7-5][326 IAC 2-7-6] [326 IAC 1-6]

- (a) The Permittee is required to implement a compliance monitoring plan to ensure that reasonable information is available to evaluate its continuous compliance with applicable requirements. This compliance monitoring plan is comprised of:
- (1) This condition;
 - (2) The Compliance Determination Requirements in Section D of this approval;
 - (3) The Compliance Monitoring Requirements in Section D of this approval;
 - (4) The Record Keeping and Reporting Requirements in Section C (Monitoring Data Availability, General Record Keeping Requirements, and General Reporting Requirements) and in Section D of this approval; and
 - (5) A Compliance Response Plan (CRP) for each compliance monitoring condition of this approval. CRP's shall be submitted to IDEM, OAM upon request and shall be subject to review and approval by IDEM, OAM. The CRP shall be prepared within ninety (90) days after issuance of this approval by the Permittee and maintained on site, and is comprised of :

- (A) Response steps that will be implemented in the event that compliance related information indicates that a response step is needed pursuant to the requirements of Section D of this approval; and
 - (B) A time schedule for taking such response steps including a schedule for devising additional response steps for situations that may not have been predicted.
- (b) For each compliance monitoring condition of this approval, appropriate response steps shall be taken when indicated by the provisions of that compliance monitoring condition. Failure to perform the actions detailed in the compliance monitoring conditions or failure to take the response steps within the time prescribed in the Compliance Response Plan, shall constitute a violation of the approval unless taking the response steps set forth in the Compliance Response Plan would be unreasonable.
- (c) After investigating the reason for the excursion, the Permittee is excused from taking further response steps for any of the following reasons:
 - (1) The monitoring equipment malfunctioned, giving a false reading. This shall be an excuse from taking further response steps providing that prompt action was taken to correct the monitoring equipment.
 - (2) The Permittee has determined that the compliance monitoring parameters established in the approval conditions are technically inappropriate, has previously submitted a request for an administrative amendment to the approval, and such request has not been denied or;
 - (3) An automatic measurement was taken when the process was not operating; or
 - (4) The process has already returned to operating within "normal" parameters and no response steps are required.
- (d) Records shall be kept of all instances in which the compliance related information was not met and of all response steps taken. In the event of an emergency, the provisions of 326 IAC 2-7-16 (Emergency Provisions) requiring prompt corrective action to mitigate emissions shall prevail.

C.9 Actions Related to Noncompliance Demonstrated by a Stack Test [326 IAC 2-7-5]
[326 IAC 2-7-6]

- (a) When the results of a stack test performed in conformance with Section C - Performance Testing, of this approval exceed the level specified in any condition of this approval, the Permittee shall take appropriate corrective actions. The Permittee shall submit a description of these corrective actions to IDEM, OAM, within thirty (30) days of receipt of the test results. The Permittee shall take appropriate action to minimize emissions from the affected facility while the corrective actions are being implemented. IDEM, OAM shall notify the Permittee within thirty (30) days, if the corrective actions taken are deficient. The Permittee shall submit a description of additional corrective actions taken to IDEM, OAM within thirty (30) days of receipt of the notice of deficiency. IDEM, OAM reserves the authority to use enforcement activities to resolve noncompliant stack tests.
- (b) A retest to demonstrate compliance shall be performed within one hundred twenty (120) days of receipt of the original test results. Should the Permittee demonstrate to IDEM, OAM that retesting in one-hundred and twenty (120) days is not practicable, IDEM, OAM may extend the retesting deadline. Failure of the second test to demonstrate

compliance with the appropriate approval conditions may be grounds for immediate revocation of the approval to operate the affected facility.

The documents submitted pursuant to this condition do not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

C.10 Monitoring Data Availability [326 IAC 2-7-6(1)] [326 IAC 2-7-5(3)]

- (a) With the exception of performance tests conducted in accordance with Section C-Performance Testing, all observations, sampling, maintenance procedures, and record keeping, required as a condition of this approval shall be performed at all times the equipment is operating at normal representative conditions.
- (b) As an alternative to the observations, sampling, maintenance procedures, and record keeping of subsection (a) above, when the equipment listed in Section D of this approval is not operating, the Permittee shall either record the fact that the equipment is shut down or perform the observations, sampling, maintenance procedures, and record keeping that would otherwise be required by this approval.
- (c) If the equipment is operating but abnormal conditions prevail, additional observations and sampling should be taken with a record made of the nature of the abnormality.
- (d) If for reasons beyond its control, the operator fails to make required observations, sampling, maintenance procedures, or record keeping, reasons for this must be recorded.
- (e) At its discretion, IDEM may excuse such failure providing adequate justification is documented and such failures do not exceed five percent (5%) of the operating time in any quarter.
- (f) Temporary, unscheduled unavailability of staff qualified to perform the required observations, sampling, maintenance procedures, or record keeping shall be considered a valid reason for failure to perform the requirements stated in (a) above.

C.11 General Record Keeping Requirements [326 IAC 2-7-5(3)][326 IAC 2-7-6]

- (a) Records of all required monitoring data and support information shall be retained for a period of at least five (5) years from the date of monitoring sample, measurement, report, or application. These records shall be kept at the source location for a minimum of three (3) years and available upon the request of an IDEM, OAM, representative. The records may be stored elsewhere for the remaining two (2) years as long as they are available upon request. If the Commissioner makes a written request for records to the Permittee, the Permittee shall furnish the records to the Commissioner within a reasonable time.
- (b) Records of required monitoring information shall include, where applicable:
 - (1) The date, place, and time of sampling or measurements;
 - (2) The dates analyses were performed;
 - (3) The company or entity performing the analyses;
 - (4) The analytic techniques or methods used;

- (5) The results of such analyses; and
- (6) The operating conditions existing at the time of sampling or measurement.
- (c) Support information shall include, where applicable:
 - (1) Copies of all reports required by this approval;
 - (2) All original strip chart recordings for continuous monitoring instrumentation;
 - (3) All calibration and maintenance records;
 - (4) Records of preventive maintenance shall be sufficient to demonstrate that failure to implement the Preventive Maintenance Plan did not cause or contribute to a violation of any limitation on emissions or potential to emit. To be relied upon subsequent to any such violation, these records may include, but are not limited to: work orders, parts inventories, and operator's standard operating procedures. Records of response steps taken shall indicate whether the response steps were performed in accordance with the Compliance Response Plan required by Section C - Compliance Monitoring Plan - Failure to take Response Steps, of this approval, and whether a deviation from an approval condition was reported. All records shall briefly describe what maintenance and response steps were taken and indicate who performed the tasks.
- (d) All record keeping requirements not already legally required shall be implemented within ninety (90) days of approval issuance.

C.12 General Reporting Requirements [326 IAC 2-7-5(3)(C)]

- (a) The reports required by conditions in Section D of this approval shall be submitted to:

Indiana Department of Environmental Management
Compliance Data Section, Office of Air Management
100 North Senate Avenue, P. O. Box 6015
Indianapolis, Indiana 46206-6015
- (b) Unless otherwise specified in this approval, any notice, report, or other submission required by this approval shall be considered timely if the date postmarked on the envelope or certified mail receipt, or affixed by the shipper on the private shipping receipt, is on or before the date it is due. If the document is submitted by any other means, it shall be considered timely if received by IDEM, OAM, on or before the date it is due.
- (c) Unless otherwise specified in this approval, any quarterly report shall be submitted within thirty (30) days of the end of the reporting period. The report does not require the certification by the "responsible official" as defined by 326 IAC 2-7-1(34).
- (d) The first report shall cover the period commencing on the date of issuance of this approval and ending on the last day of the reporting period.

SECTION D.1 FACILITY OPERATION CONDITIONS

Facility Description [326 IAC 2-7-5(15)]

One (1) touch up/repair/special project spray booth, identified as SB21, equipped with dry filters and exhausting to two stacks, SB21A and SB21B.
(The information describing the process contained in this facility description box is descriptive information and does not constitute enforceable conditions.)

Emission Limitations and Standards [326 IAC 2-7-5(1)]

D.1.1 Volatile Organic Compounds (VOC) [326 IAC 8-2-12]

Pursuant to 326 IAC 8-2-12 (Wood Furniture and Cabinet Coating), the surface coating applied to wood furniture and cabinets shall utilize one of the following application methods:

- Airless Spray Application
- Air Assisted Airless Spray Application
- Electrostatic Spray Application
- Electrostatic Bell or Disc Application
- Heated Airless Spray Application
- Roller Coating
- Brush or Wipe Application
- Dip-and-Drain Application

High Volume Low Pressure (HVLP) Spray Application is an accepted alternative method of application for Air Assisted Airless Spray Application. HVLP spray is the technology used to apply coating to substrate by means of coating application equipment which operates between one-tenth (0.1) and ten (10) pounds per square inch gauge (psig) air pressure measured dynamically at the center of the air cap and at the air horns of the spray system.

D.1.2 Prevention of Significant Deterioration [326 IAC 2-2] [40 CFR 52.21]

Any change or modification to spray booth SB21, that will cause potential emissions of

- (a) 25.0 tons per year or more of particulate matter (PM), or
- (b) 15.0 tons per year or more of particulate matter less than ten (10) microns (PM10), or
- (c) 40.0 tons per year or more of volatile organic compounds (VOCs),

must have prior approval from the Office of Air Management, pursuant to 326 IAC 2-2 (40 CFR 52.21).

D.1.3 Particulate Matter (PM) [326 IAC 6-3-2(c)]

The particulate matter (PM) from the spray booth (SB21) shall be limited by the following:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67}$$

where E = rate of emission in pounds per hour and
P = process weight rate in tons per hour

D.1.4 Preventive Maintenance Plan [326 IAC 2-7-5(13)]

A Preventive Maintenance Plan, in accordance with Section B - Preventive Maintenance Plan, of this permit, is required for this facility and any control devices.

Compliance Determination Requirements

D.1.5 Testing Requirements [326 IAC 2-7-6(1),(6)][326 IAC 2-1.1-11]

The Permittee is not required to test this facility by this permit. However, IDEM may require compliance testing when necessary to determine if the facility is in compliance. If testing is required by IDEM, compliance with the particulate matter (PM) and volatile organic compound (VOC) limit specified in Conditions D.1.2 and D.1.3 shall be determined by a performance test conducted in accordance with Section C - Performance Testing.

Compliance Monitoring Requirements [326 IAC 2-7-6(1)] [326 IAC 2-7-5(1)]

D.1.6 Particulate Matter (PM)

The dry filters for PM control shall be in operation at all times when the spray booth (SB21) is in operation.

D.1.7 Monitoring

- (a) Daily inspections shall be performed to verify the placement, integrity and particle loading of the filters. To monitor the performance of the dry filters, weekly observations shall be made of the overspray from the spray booth stacks (SB21A and SB21B) while one or more of the booths are in operation. The Compliance Response Plan shall be followed whenever a condition exists which should result in a response step. Failure to take response steps in accordance with Section C - Compliance Monitoring Plan - Failure to Take Response Steps, shall be considered a violation of this permit.
- (b) Monthly inspections shall be performed of the coating emissions from the stack and the presence of overspray on the rooftops and the nearby ground. The Compliance Response Plan for this unit shall contain troubleshooting contingency and response steps for when a noticeable change in overspray emission, or evidence of overspray emission is observed. The Compliance Response Plan shall be followed whenever a condition exists which should result in a response step. Failure to take response steps in accordance with Section C - Compliance Monitoring Plan - Failure to Take Response Steps, shall be considered a violation of this permit.
- (c) Additional inspections and preventive measures shall be performed as prescribed in the Preventive Maintenance Plan.

Record Keeping and Reporting Requirements [326 IAC 2-7-5(3)] [326 IAC 2-7-19]

D.1.8 Record Keeping Requirements

- (a) To document compliance with Condition D.1.7, the Permittee shall maintain a log of weekly overspray observations, daily and monthly inspections, and those additional inspections prescribed by the Preventive Maintenance Plan.
- (b) All records shall be maintained in accordance with Section C - General Record Keeping Requirements, of this permit.

**INDIANA DEPARTMENT OF ENVIRONMENTAL MANAGEMENT
OFFICE OF AIR MANAGEMENT
COMPLIANCE DATA SECTION**

**PART 70 SOURCE MODIFICATION
CERTIFICATION**

Source Name: Kimball Office Casegoods Manufacturing - Salem
Source Address: Hwy. 56 East, Salem, Indiana 47617
Mailing Address: 200 Kimball Boulevard, Salem, Indiana 47167
Source Modification No.: 175-11390-00007

This certification shall be included when submitting monitoring, testing reports/results or other documents as required by this approval.

Please check what document is being certified:

- 9 Test Result (specify) _____
- 9 Report (specify) _____
- 9 Notification (specify) _____
- 9 Other (specify) _____

I certify that, based on information and belief formed after reasonable inquiry, the statements and information in the document are true, accurate, and complete.

Signature:

Printed Name:

Title/Position:

Date:

**Indiana Department of Environmental Management
Office of Air Management**

**Technical Support Document (TSD) for a
Part 70 Minor Source Modification**

Source Background and Description

Source Name:	Kimball Office Casegoods Manufacturing - Salem
Source Location:	Hwy. 56 East, Salem, Indiana 47617
County:	Washington
SIC Code:	2521
Operation Permit No.:	T 175-6062-00007
Operation Permit Issuance Date:	not issued yet
Minor Source Modification No.:	175-11390-00007
Permit Reviewer:	Kimberly Titzer

The Office of Air Management (OAM) has reviewed a modification application from Kimball Office Casegoods Manufacturing - Salem relating to the construction of the following emission units and pollution control devices:

One (1) touch up/repair/special project spray booth, identified as SB21, equipped with dry filters and exhausting to two stacks, SB21A and SB21B.

History

On September 29, 1999, Kimball Office Casegoods Manufacturing - Salem submitted an application to the OAM requesting to add an additional touch up/repair/special project spray booth to their existing plant. At the time of this review, Kimball Office Casegoods Manufacturing - Salem had not been issued a Part 70 Operating Permit.

Enforcement Issue

There are no enforcement actions pending.

Stack Summary

Stack ID	Operation	Height (feet)	Diameter (inches)	Flow Rate (acfm)	Temperature (°F)
SB21A	spray booth	30	2-36	16,000	ambient
SB21B	spray booth	30	2-36	16,000	ambient

Recommendation

The staff recommends to the Commissioner that the Part 70 Minor Source Modification be approved. This recommendation is based on the following facts and conditions:

Unless otherwise stated, information used in this review was derived from the application and additional information submitted by the applicant.

An application for the purposes of this review was received on September 29, 1999.

Emission Calculations

See Appendix A of this document for detailed emissions calculations (page 6).

Potential To Emit of Modification

Pursuant to 326 IAC 2-1.1-1(16), Potential to Emit is defined as “the maximum capacity of a stationary source to emit any air pollutant under its physical and operational design. Any physical or operational limitation on the capacity of a source to emit an air pollutant, including air pollution control equipment and restrictions on hours of operation or type or amount of material combusted, stored, or processed shall be treated as part of its design if the limitation is enforceable by the U. S. EPA.”

This table reflects the PTE before controls. Control equipment is not considered federally enforceable until it has been required in a federally enforceable permit.

Pollutant	Potential To Emit (tons/year)
PM	<25 for each material
PM-10	<25 for each material
SO ₂	0
VOC	<25 for each material
CO	0
NO _x	0

HAP's	Potential To Emit (tons/year)
<i>Formaldehyde</i>	<10
<i>Xylene</i>	<10
<i>Methyl Isobutyl Ketone</i>	<10
<i>Combined HAPs</i>	<25

Justification for Modification

The Part 70 Operating permit is being modified through a Part 70 Minor Source Modification. This modification is being performed pursuant to 326 IAC 2-7-10.5(d)(4), where emissions are less than twenty-five (25) tons per year for particulate matter (PM), particulate matter less than ten (10) microns (PM10) and less than ten (10) tons per year of a single hazardous air pollutant (HAP) and less than twenty-five (25) tons per year of combined HAPs. The spray booth is only capable of using one material at a time. Therefore, volatile organic compound (VOC) emissions are based on individual materials. Each material used emits less than twenty-five (25) tons per year of VOCs.

County Attainment Status

The source is located in Washington County.

Pollutant	Status
PM-10	attainment
SO ₂	attainment
NO ₂	attainment
Ozone	attainment
CO	attainment
Lead	attainment

- (a) Volatile organic compounds (VOC) and oxides of nitrogen (NO_x) are precursors for the formation of ozone. Therefore, VOC and NO_x emissions are considered when evaluating the rule applicability relating to the ozone standards. Washington County has been designated as attainment or unclassifiable for ozone. Therefore, VOC and NO_x emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2 and 40 CFR 52.21.
- (b) Washington County has been classified as attainment for all criteria pollutants. Therefore, these emissions were reviewed pursuant to the requirements for Prevention of Significant Deterioration (PSD), 326 IAC 2-2 and 40 CFR 52.21.

- (c) **Fugitive Emissions**
 Since this type of operation is not one of the 28 listed source categories under 326 IAC 2-2 and since there are no applicable New Source Performance Standards that were in effect on August 7, 1980, the fugitive PM emissions are not counted toward determination of PSD and Emission Offset applicability.

Source Status

Existing Source PSD or Emission Offset Definition (emissions after controls, based upon 8760 hours of operation per year at rated capacity and/or as otherwise limited):

	Limited Potential to Emit (tons/year)						
Process/facility	PM	PM-10	SO ₂	VOC	CO	NO _x	HAPs
spray booths				250 TPY			
woodworking	9.91lb/hr						
tri-fuel boilers	0.35 lb/ mmBtu		6.0 lb/ mmBtu				

This existing source is a major stationary source because an attainment regulated pollutant is emitted at a rate of 250 tons per year or more, and it is not one of the 28 listed source categories.

These emissions are based upon emission calculations for the draft Part 70 Operating Permit (175-6062) and emission calculations for the Minor Source Modification (175-11390).

Potential to Emit of Modification After Issuance

The table below summarizes the potential to emit, reflecting all limits, of the significant emission units after controls. The control equipment is considered federally enforceable only after issuance of this Part 70 source modification.

	Potential to Emit (tons/year)						
Process/facility	PM	PM-10	SO ₂	VOC	CO	NO _x	HAPs
SB21 spray booth	<25.0	<15.0		<40.0			

This modification to an existing major stationary source is not major because the emission increase is less than the PSD significant levels. Therefore, pursuant to 326 IAC 2-2, and 40 CFR 52.21, the PSD requirements do not apply.

Federal Rule Applicability

- (a) There are no New Source Performance Standards (NSPS)(326 IAC 12 and 40 CFR Part 60) applicable to this proposed modification.
- (b) There are no National Emission Standards for Hazardous Air Pollutants (NESHAPs)(326 IAC 14 and 40 CFR Part 63) applicable to this proposed modification.
- (c) The National Emission Standards for Wood Furniture Manufacturing Operations (40 CFR 63, Subpart JJ) does not apply to this spray booth, based on potential emissions of single and combined HAPs less than ten (10) and twenty-five (25) tons per year,

respectively.

State Rule Applicability - Individual Facilities

326 IAC 2-2 (PSD)

Any change or modification to spray booth SB21, that will cause potential emissions of

- (a) 25.0 tons per year or more of particulate matter (PM), or
- (b) 15.0 tons per year or more of particulate matter less than ten (10) microns (PM10), or
- (c) 40.0 tons per year or more of volatile organic compounds (VOCs),

must have prior approval from the Office of Air Management, pursuant to 326 IAC 2-2 (40 CFR 52.21).

326 IAC 6-3-2 (Process Operations)

The particulate matter (PM) from the spray booth (SB21) shall be limited by the following:

Interpolation of the data for the process weight rate up to sixty thousand (60,000) pounds per hour shall be accomplished by use of the equation:

$$E = 4.10 P^{0.67} \quad \text{where } E = \text{rate of emission in pounds per hour and} \\ P = \text{process weight rate in tons per hour}$$

The dry filters shall be in operation at all times the spray booth is in operation, in order to comply with this limit.

326 IAC 8-2-12 (Wood Furniture and Cabinet Coating)

Pursuant to 326 IAC 8-2-12 (Wood Furniture and Cabinet Coating), the surface coating applied to wood furniture and cabinets shall utilize one of the following application methods:

- Airless Spray Application
- Air Assisted Airless Spray Application
- Electrostatic Spray Application
- Electrostatic Bell or Disc Application
- Heated Airless Spray Application
- Roller Coating
- Brush or Wipe Application
- Dip-and-Drain Application

High Volume Low Pressure (HVLP) Spray Application is an accepted alternative method of application for Air Assisted Airless Spray Application. HVLP spray is the technology used to apply coating to substrate by means of coating application equipment which operates between one-tenth (0.1) and ten (10) pounds per square inch gauge (psig) air pressure measured dynamically at the center of the air cap and at the air horns of the spray system.

The source is in compliance because accepted applications are used.

No other 8 rules apply to this source.

Compliance Requirements

Permits issued under 326 IAC 2-7 are required to ensure that sources can demonstrate compliance with applicable state and federal rules on a more or less continuous basis. All state and federal rules contain compliance provisions, however, these provisions do not always fulfill the requirement for a more or less continuous demonstration. When this occurs IDEM, OAM, in conjunction with the source, must develop specific conditions to satisfy 326 IAC 2-7-5. As a result, compliance requirements are divided into two sections: Compliance Determination Requirements and Compliance Monitoring Requirements.

Compliance Determination Requirements in Section D of the permit are those conditions that are found more or less directly within state and federal rules and the violation of which serves as grounds for enforcement action. If these conditions are not sufficient to demonstrate continuous compliance, they will be supplemented with Compliance Monitoring Requirements, also Section D of the permit. Unlike Compliance Determination Requirements, failure to meet Compliance Monitoring conditions would serve as a trigger for corrective actions and not grounds for enforcement action. However, a violation in relation to a compliance monitoring condition will arise through a source's failure to take the appropriate corrective actions within a specific time period.

The compliance monitoring requirements applicable to this modification are as follows:

1. The dry filters used as overspray control for the spray booth has applicable compliance monitoring conditions as specified below:
 - (a) Daily inspections shall be performed to verify the placement, integrity and particle loading of the filters. To monitor the performance of the dry filters, weekly observations shall be made of the overspray from the surface coating booth stacks while the booths are in operation. The Compliance Response Plan shall be followed whenever a condition exists which should result in a response step. Failure to take response steps in accordance with Section C - Compliance Monitoring Plan - Failure to Take Response Steps, shall be considered a violation of this permit.
 - (b) Monthly inspections shall be performed of the coating emissions from the stack and the presence of overspray on the rooftops and the nearby ground. The Compliance Response Plan for this unit shall contain troubleshooting contingency and response steps for when a noticeable change in overspray emission, or evidence of overspray emission is observed. The Compliance Response Plan shall be followed whenever a condition exists which should result in a response step. Failure to take response steps in accordance with Section C - Compliance Monitoring Plan - Failure to Take Response Steps, shall be considered a violation of this permit.
 - (c) Additional inspections and preventive measures shall be performed as prescribed in the Preventive Maintenance Plan.

Conclusion

The construction of this proposed modification shall be subject to the conditions of the attached proposed Part 70 Minor Source Modification No. 175-11390-00007.

